Fi

Combustible Waste Material: 2019 CFC 3107.19

The floor surface inside tents and the grounds outside and within 30 feet in perimeter shall be kept free of combustible waste and other combustible materials that could create a fire hazard.

Clearance: 2019 CFC 3107.,J 0 Tc 0 0 (m)-1- (,J (e)10)Tj E0/Artifactc[(e)10

10) Solid fuel cooking shall be a minimum of 20 feet from any structure, overhang, or fabric.
11) No combustible or flammable liquids shall be heated directly on any heater or cooking appliance. Substance such as candle wax shall be melted in containers set in boiling water (double boiler) to keep the wax from reaching its ignition temperature.
12) All deep fryers and other cooking appliances (i.e. pots, pans, woks, etc.) with a capacity of one (1) gallon (4 quarts) of cooking oil or more shall be kept outside of tents, trailers, or the like and placed a minimum of 20 feet away or shall be located under a commercial kitchen hood provided with a U.L. 300 compliant fire extinguishing system bearing an approved service label as certified by the Office of the State Fire Marshal.

Compressed Gas Cylinders: 2019 CFC 3107.13 -3107.13.3

1) Propane fired devices must be approved by Underwriters Laboratories (UL) or by the American Gas Association (AGA). These labels must be accessible for inspection.
2) Liquefied Petroleum (LP) gas containers of 500 gallons or less shall be located outside of the tent with a minimum separation distance of least 10 feet between container and structure and shall have the safety release valve pointed away from the tent.
3) Liquefied Petroleum (LP) gas containers of 500 gallons or more shall be located outside of the tent with a minimum separation distance of least 25 feet between container and structure and shall have the safety release valve pointed away from the tent.
4) All cylinders shall be stored in an upright position, adequately secured in place and protected to prevent accidental tip-over, tampering, unauthorized movement and damage by vehicles or other hazards.
5) Cylinders not in use shall be capped.
6) All compressed gas cylinders in use shall be equipped with individual regulators with approved hose and appliances.
7) All L.P. gas cylinders shall be within current hydrostatic test date, (no more than 12 years

Exits shall be clearly marked with exit signs in tents having an occupant load of 50 or more. Illuminated exit signs shall be installed at all required exit doorways for occupant lads of 51 to 299 person or as determined by the fire code official. Illuminated exit signs shall be an approved self-luminous type or shall be internally illuminated. Two separate circuits are required, one of which separate from all other circuits. For occupant loads of 300 or more, two separate sources of power, one of which is an emergency system consisting of onsite storage batteries or and on site generator, shall be provided.

Emergency Lighting 2019 CFC 3103.12.6.1

Means of egress illumination shall be provided whenever the tent is occupied. An intensity of not less than one foot-candle at floor level is required. Fixtures shall be supplied form a separate circuit or source of power. In the event of power failure an emergency electrical system shall automatically illuminate the means of egress system.

Parking of Vehicles Title 19, 312 & 2019 CFC 3103.8.2

Vehicles necessary to the operation of the establishment and parked on a public street shall be parked at least 20 feet from any tent. No other vehicles shall be parked less than 100 feet from any tent.